



R.A.I. - C.P.S VIA ASIAGO - PIANO RIALZATO - U.O. PSICHIATRIA

Rif. n°	DESTINAZIONE D'USO DEI LOCALI	S locale	MQ locale	S finestra AERANTE	S finestra ILLUMINANTE	MQ Sup. A	MQ Sup. I	S.A. finestra > 1/10 S locale	S.I. finestra > 1/10 S locale
1	CENTRALINO	2.20 X 3.70	8	(0.80 X 1.05) + (0.30 X 1.60)	1.60 X 1.35	1.32	2.16	1.32 > 0.8	2.16 > 0.8
2	SALA ATTESA	3.07 X 3.70	11	(0.80 X 1.05) + (0.30 X 1.60)	1.60 X 1.35	1.32	2.16	1.32 > 1.1	2.16 > 1.1
3	LOCALE CAPOSALA	4.80 X 3.70	17.8	(0.80 X 1.05) + (0.30 X 1.60) X2	(1.60 X 1.35) X2	2.64	4.32	2.64 > 1.78	4.32 > 1.78
4	LOCALE VISITA MEDICA	2.50 X 3.70	9	(0.80 X 1.05) + (0.30 X 1.60)	1.60 X 1.35	1.32	2.16	1.32 > 0.9	2.16 > 0.9
5	LOCALE VISITA MEDICA	2.70 X 3.70	10	(0.80 X 1.05) + (0.30 X 1.60)	1.60 X 1.35	1.32	2.16	1.32 > 1	2.16 > 1
6	LOCALE VISITA MEDICA	2.50 X 3.70	9	(0.80 X 1.05) + (0.30 X 1.60)	1.60 X 1.35	1.32	2.16	1.32 > 0.9	2.16 > 0.9
7	SPOGLIATOIO	(3.20 X + 2.43 X 1.70)	10	(0.80 X 1.05) + (0.30 X 1.60)	1.60 X 1.35	1.32	2.16	1.32 > 1	2.16 > 1
8	SALA MEDICA	(4.00 X 3.50) + (0.80 X 2.0) - (0.50 X 3.5)	16.7	(1.65 X 1.35) + (0.30 X 0.85) X2	(1.65 X 1.35) + (0.30 X 0.85)	2.35	2.48	2.35 > 1.67	2.48 > 1.67
9	ACCOGLIENZA SEGRETERIA - spazio archivio -	5.20 X 5.20	27	(1.60 X 1.30) + (0.60 X 1.65)	4.00 X 1.30	2.92	5.20	2.92 > 2.7	5.20 > 2.7
10	LOCALE PER ATTIVITA' TERAPEUTICHE	5.20 X 5.20	27	(1.60 X 1.30) + (0.60 X 1.65)	4.00 X 1.30	2.92	5.20	2.92 > 2.7	5.20 > 2.7
11	LOCALE PER RIUNIONI	5.20 X 5.20	27.5	(1.60 X 1.30) + (0.60 X 1.65)	4.00 X 1.30	2.92	5.20	2.92 > 2.75	5.20 > 2.75
12	WC UTENTI	(3.20 X 3.40) - (1.05 X 1.50)	11.4	(0.65 X 0.60) X3/2	(0.65 X 0.60) X3	0.76	1.53	0.76 > 1.14	1.53 > 1.14
13	WC PERSONALE	1.32 X 3.40	4.4	(0.65 X 0.60) X2/2	(0.65 X 0.60) X2	0.51	1.02	0.51 > 0.44	1.02 > 0.44

R.A.I. - C.P.S VIA ASIAGO - PIANO SEMINTERRATO - U.O. PSICHIATRIA

Rif. n°	DESTINAZIONE D'USO DEI LOCALI	S locale	MQ locale	S finestra AERANTE	S finestra ILLUMINANTE	MQ Sup. A	MQ Sup. I	S.A. finestra > 1/10 S locale	S.I. finestra > 1/10 S locale
14	MAGAZZINO - SPP -	3.20 X 3.20	10	0.85 X 1.20	(0.65 X 1.20) X3	1.02	3.06	1.02 > 1	3.06 > 1
15	MAGAZZINO - SPP -	3.45 X 3.20	11	0.85 X 1.20	(0.65 X 1.20) X3	1.02	3.06	1.02 < 1.1	3.06 > 1.3
16	STUDIO PSICOLOGO	3.95 X 3.20	12.60	(0.85 X 1.20) X2	(0.65 X 1.20) X4	2.04	4.08	2.04 > 1.26	4.08 > 1.1
17	SALA DA PRANZO	non climatizzata (3.95 X 3.20) - (2.4 X 1.35) - (2.4 X 1.35)	/	(0.85 X 1.20) X2	(0.65 X 1.20) X5	2.04	3.05		
18	LAVANDERIA	(0.90 X 0.25) X3 - (2.1 X 0.75) - (2.4 X 1.35)	14	0.85 X 1.20	(0.65 X 1.20) X3	1.02	3.06	1.02 > 1.4	3.06 > 1.4
19	CUCINA	(0.90 X 0.25) X3 - (2.1 X 0.75) - (2.4 X 1.35)	22.8	(0.85 X 1.00) X3 - (0.75 X 2.10)	(0.65 X 1.00) X4 + (0.75 X 2.10)	2.8	3.95	2.8 > 2.28	3.95 > 2.28
20	STUDIO PSICOLOGO	5.20 X 5.20	27	(0.85 X 1.00) X2 + (0.75 X 2.10)	(0.65 X 1.00) X4 + (0.75 X 2.10)	3.27	4.97	3.27 > 2.7	4.97 > 2.7
21	SALA RELAX	5.20 X 5.20	27	(0.85 X 1.00) X2 + (0.75 X 2.10)	(0.65 X 1.00) X4 + (0.75 X 2.10)	3.27	4.97	3.27 > 2.7	4.97 > 2.7
22	ATELIER	5.00 X 5.20	26	(0.85 X 1.00) X2 + (0.75 X 2.10)	(0.65 X 1.00) X4 + (0.75 X 2.10)	3.27	4.97	3.27 > 2.6	4.97 > 2.6
23	WC PAZIENTI	3.80 X 2.32	10.7	0.85 X 0.65	(0.65 X 0.65) X2	0.55	1.1	0.55 > 1	1.1 > 1
24	WC OPERATORI	1.20 X 1.32	1.6	(0.65 X 0.65) X2	0.65 X 0.65	0.3	0.55	0.3 > 0.16	0.55 > 0.16

TUTTE LE ALTEZZE DEI LOCALI SONO SUPERIORI A 3m

